

REGISTERED ELECTRICAL ENGINEER DATE 2/22/08

PLANS APPROVAL DATE

PB AMERICAS, Inc.
A Parsons Brinckerhoff Company
303 Second St., Suite 700N
San Francisco, CA 94107-1317


The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.

Caltrans now has a web site! To get to the web site, go to <http://www.dot.ca.gov>

- ① Type I, for cable tray supports details, see AS sheets.
- ② Type II, for cable tray supports details, see AS sheets.
- ③ Type V, for cable tray supports details, see AS sheets.
- ④ Type VI, for cable tray supports details, see AS sheets.
- ⑤ The Contractor to provide cable tray support at each ends of cable tray fitting as required
- ⑥ Type VII, for cable tray supports details, see AS sheets.
- ⑦ Type VIIA, for cable tray supports details, see AS sheets.
- ⑧ Type VIIB, for cable tray supports details, see AS sheets.
- ⑨ Contractor to provide approved type of sealing compound after cables are pulled. Empty conduits shall have threaded cap at both ends.
- ⑩ Pull Box PB-2A shall be located on top of stiffener. The Contractor shall provide strut channel for support installed in field.
- ⑪ The Contractor shall provide strut channel on top of stiffener for conduit support and installed in field.
- ⑫ The Contractor to provide insulated grounding bushing at each end of the conduit.
- ⑬ The Contractor to provide secondary support installed in field, see detail 2 on dwg E-207D.
- ⑭ Cable tray tee fitting shall have 305 mm radius.
- ⑮ For cable tray support see AS-Sheets.

Scale 1:50

CONTRACT CHANGE ORDER NO. _____
SHEET _____ OF _____



FOR REVISION ONLY

Cable Tray Support and Crossbeam
 PANEL POINT PP 14
 Scale 1:50



E - 207 A

THIS PLAN ACCURATE FOR ELECTRICAL WORK ONLY.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE SHOWN.

FOR REDUCED PLANS ORIGINAL
SCALE IS IN MILLIMETERS

DGN FILE =>T:\3103\MS\pse\SAS Struc\CCO\SAS CCO55\2008-12-22_	Issued for Submittal\04-0120f1_	0232501R01.dgn
USERNAME =>llorico	CU 04251	EA 0120F1

00-00-00	DATE PLOTTED => 12/22/2008
LAST REVISION	TIME PLOTTED => 10:19:28 AM